

From: Paul Jackson
To: dc@ryedale.gov.uk
Date: 30/09/2008 16:47
Subject: 08/00835/FUL - Gilling East

Please excuse the rushed nature of these comments.

1) Whilst I appreciate that the light green colour of the profiled sheeting on the walls and roof will match the existing colour scheme, I would prefer to see a dark colour used. The building will be visible within the woodland during the winter months (when the leaves are off the trees) and at that time of year the wood will appear dark when viewed from across the valley. A light-coloured building will therefore stand out more and, whilst not objecting to the extension per se, I would prefer not to see an increase in the VISUAL bulk.

2) The proposed additional access/security lighting should be of modern standards as regards light pollution, with side and top baffles in order to prevent light-spill. Consideration should be given to putting this extra lighting on sensors, to reduce the amount of time that it is on and hence the light emissions.

Paul Jackson
Howardian Hills AONB Manager
The Mews, Wath Court
Hovingham
York
YO62 4NN

Tel: 0845 034 9495 / NYCC Extn 6775
Mob: 07715 009426
Website: www.howardianhills.org.uk