

Fire Precautions

16. No unit should be further than 90 metres from a fire point. At each fire point there should be two water (gas expelled) extinguishers each of 10 litres capacity and complying with British Standard 5423 : 1980 together with a means of raising the alarm in the event of fire (eg a manually operated sounder, gong or hand operated siren). All fire fighting equipment susceptible to damage by frost should be suitably protected.
17. Wherever there is a likelihood of fire spreading due to vegetation catching fire, suitable beaters, of the type used by the Forestry Commission, should also be provided at each fire point.
18. The fire points should be clearly marked and easily accessible. All firefighting equipment should be maintained in working order and kept available for use and for inspection by the licensing authority.
19. Each fire point should exhibit a conspicuous notice indicating the action to be taken in case of fire and the location of the nearest telephone. The notice should include the following:
 - ii Raise the alarm
 - iii Ensure the affected unit is evacuated
 - iiii Call the Fire Brigade (the nearest telephone is sited
 - iv If practicable, attack the fire using the firefighting equipment provided.

Liquefied Petroleum Gas

20. Arrangements for the storage of Liquefied Petroleum Gas (LPG) on the site should be in accordance with the current national Code of Practice and regulations.

Site Notices

21. A sign indicating the name of the site should be displayed at the site entrance.
22. Notices should be displayed prominently on the site indicating the action to be taken in the event of an emergency and show where the police, fire brigade, ambulance, and local doctors can be contacted, and the location of the nearest public telephone. Where practicable a telephone should be provided on the site and the full address of the site should be displayed near the telephone.
23. At sites subject to flood risk, warning notices should be displayed giving advice about the operation of the flood warning system.
24. At sites with overhead electric lines, warning notices should be displayed on the supports for the lines and at the site entrance. Where appropriate, these should warn against the danger of contact between the lines and the masts of yachts or dinghies.
25. A copy of the site licence with its conditions should be displayed prominently on the site.